

AFFIDAVIT OF Pamela Stansbury

STATE OF NEW YORK)
) ss.
COUNTY OF TOMPKINS)

Pamela Stansbury being of full age and duly sworn, deposes and says as follows:

1. I am an employee of the Cornell University Library, and specifically Library Technical Services, located at Cornell University, Ithaca, New York 14853. I have personal knowledge of the facts set forth below.
2. I am the Administrative Supervisor in Library Technical Services, which maintains bibliographical and processing information for many historical documents. I have held such position since 1996.
3. Included in the Library's historical collection are various publications. As part of that collection, the Library maintains custody of an original issue of **Applied optics, Volume 10, Number 1, January 1971**, which includes the paper **Photoluminescent conversion of laser light for black and white and multicolor displays. 2: Systems** / by D.A. Pinnow, L.G. Van Uitert, and M. Feldman.
4. Mr. Richard F. Moncrief requested information about **Applied optics, Volume 10, Number 1, January 1971** – specifically when this item was first made publicly available by the Library. As best I can determine, the publication was publicly available at the Cornell University Library as January 5, 1971.

Pamela J. Stansbury (signature)
Pamela J. Stansbury (name printed)

Sworn to before me this
30th day of November 2016


Andrea Denise Smith Colon
Notary Public

ANDREA DENISE SMITH COLON
NOTARY PUBLIC-STATE OF NEW YORK
Tompkins County
Registration #01SM6276256
Commission Exp. 02/11/2017

BC
350
65+

Applied Optics

January
1971



CHROMATICITY DIAGRAM

Applied Optics

VOLUME 10
NUMBER 1
JANUARY
1971

A monthly publication of the
Optical Society of America

J. N. Howard Editor

P. R. Wakeling Managing Editor

Cover: See page 153.

Published monthly by the Optical Society of America at 20th and Northampton Streets, Easton, Pa. 18042. Office of the Editor: AFCRL, Bedford, Mass. 01730; 617-861-4281. Office of the Managing Editor: WINC, 1613 Nineteenth Street, N.W., Washington, D.C. 20009; 202-387-1773. Advertising office: American Institute of Physics, 335 E. 45th Street, New York, N.Y. 10017; 212-MU 5-1940. Subscription rates per year: included in membership dues to OSA members; nonmembers and libraries \$35. Single copies \$4; complete volumes \$40. Second class postage paid at Easton, Pa. © Copyright 1970 by the Optical Society of America, Inc.

- 1 Geodesic Chromaticity Diagram Based on Variances of Color Matching by 14 Normal Observers—D. L. MacAdam
- 8 A Visual Tristimulus Projection Colorimeter—A. Valberg
- 14 Adjustment of the Munsell-Value and W^* -Scales to Uniform Lightness Steps for Various Background Reflectances—C. C. Semmelroth
- 19 Internal Reflection Spectroscopy: Validity of Effective Thickness Equations—N. J. Harrick and A. I. Carlson
- 24 Hadamard-Transform Exhaust-Analysis Spectrometer—J. A. Decker, Jr.
- 28 A Grazing Incidence Monochromator for Satellite Studies of the Solar Hell Lyman- α Line at 303.8 Å—P. J. Bowen, J. A. Bowles, W. M. Glencross, R. J. Speer, A. F. Timothy, J. G. Timothy, and A. P. Willmore
- 34 A Convenient Technique for Determining the Relative Quantum Efficiency of a Monochromator and Detector System—J. L. Kohl, L. J. Curtis, D. A. Chojnacki, and R. M. Schectman
- 38 Motion Blurring with Decaying Detector Response—L. Levi
- 42 Electrical Recording of the Amplitude and Phase Fluctuations of a Wave Front—M. Bertolotti
- 46 A Simple Double Beam Accessory for Absorption Spectroscopy—K. Leutwein
- 51 Spectral Absorption Characteristics of the Major Components of Dust Clouds—D. F. Flanagan and H. P. DeLong
- 58 Effects of Argon Atoms on the Self-Absorption and the Intensity of Hg 2537-Å Radiation in Hg + Ar Discharges—T. J. Hammond and C. F. Gallo
- 65 Statistical Band Model Parameters and Integrated Intensities for the 5.9- μ , 7.5- μ , and 11.3- μ Bands of HNO₂ Vapor—A. Goldman, T. G. Kyle, and F. S. Bonomo
- 74 Radiance and Polarization of Light Reflected from Optically Thick Clouds—G. W. Kattawar and G. N. Plass
- 81 Radiation-Induced Changes in Refractive Index and Absorption Coefficient for Several Optical Materials—D. R. Olson, H. D. Dieselman, and J. B. Schroeder
- 87 Damping of Lattice Vibrations in Solids—J. N. Plendl
- 99 The Correction of Optical Aberrations by Neutron Irradiation—P. Sinal
- 105 Images of Truncated One-Dimensional Periodic Bar Targets in Aberration-Limited Optical Systems—J. W. Foreman, Jr., G. H. Hunt, and E. K. Lawson
- 109 Influence of Scattered Radiation on Narrow Field of View Communication Links—D. E. Setzer
- 114 Small-Angle Scattering of Light by Ocean Water—H. T. Yura
- 119 Bidirectional Scattering Characteristics of Healthy Green Soybean and Corn Leaves *in vivo*—H. T. Breece III and R. A. Holmes
- 128 Cineholomicroscopy of Small Animal Microcirculation—M. E. Cox, R. G. Buckles, and D. Whitlow
- 132 Calorimeter for Laser Energy Measurements—M. M. Birky
- 136 The CO₂ Laser Signature Problem—P. C. Claspay and Yoh-Han Pao
- 141 CO₂ Laser with Simultaneous Active and Passive Q-Switching—O. M. Stafsudd, O. Ersoy, and S. Pizzica
- 144 A Precision Variable, Double Prism Attenuator for CO₂ Lasers—T. Oseki and S. Saito
- 150 Photoluminescent Conversion of Laser Light for Black and White and Multi-color Displays. 1: Materials—L. G. Van Uitert, D. A. Pinnow, and J. C. Williams
- 154 Photoluminescent Conversion of Laser Light for Black and White and Multi-color Displays. 2: Systems—D. A. Pinnow, L. G. Van Uitert, and M. Feldman
- 161 Measurement of the Beam Parameters of a Laser Beam and Its Diffraction Field, Using a Hologram—T. Miyamoto and K. Yasuura
- 168 A Contribution to the Comparison of Single Exposure and Multiple Exposure Storage Holograms—M. Lang, G. Goldmann, and P. Graf
- 174 Holographic Subtraction—K. Bromley, M. A. Monahan, J. F. Bryant, and B. J. Thompson
- 182 A Holographic Interferometer for Measuring Radiation Energy Deposition Profiles in Transparent Liquids—E. K. Hussmann
- 187 A Generalized Technique of Two-Wavelength, Nondiffuse Holographic Interferometry—F. Weigl
- 193 A Technique for Recovering Doppler Line Profiles from Fabry-Perot Interferometer Fringes of Very Low Density—P. B. Hays and R. G. Roble
- 201 Schlieren Visualization Device Allowing an Arbitrary Orientation of the Lines with Respect to the Scanning Direction—R. Grossin, M. Jannot, and S. Vianny

Photoluminescent Conversion of Laser Light for Black and White and Multicolor Displays. 2: Systems

D. A. Pinnow, L. G. Van Uitert, and M. Feldman

Recent technological developments permit the modulation and scanning of laser beams at rates comparable with those of electron beams in television receivers. This accounts for much of the current interest in laser illuminated display systems which are not constrained in size, as is the cathode ray tube, by the necessity of a vacuum enclosure. The purpose of the present work is to show how photoluminescent materials can be used in conjunction with recently developed acoustooptic deflectors and modulators to achieve high quality laser display systems. The principal function of the photoluminescent materials is that of color conversion when coated onto a viewing screen. This allows an additional degree of freedom in laser display engineering by removing the spectral constraints imposed by the limited number of practical laser emissions. Various schemes for both black and white and multicolor displays are explored. Some of the concepts which evolved have been experimentally verified by the operation of a system which projected the video signal from a PICTUREPHONE set. The source was an argon ion laser which emitted a monochromatic blue (4880-Å) beam. After acoustooptic modulation and deflection, the blue beam was directed to a phosphor screen where it was converted into a brighter and speckle-free black and white display.

I. Introduction

In Part 1¹ we discussed the characteristics of a number of photoluminescent materials that can efficiently convert ultraviolet and visible light into light of a similar or longer wavelength spectral content. Here we will consider the application of these materials to white light and multicolor displays that use laser sources. A considerable effort in the field of laser scanned displays has been prompted by potential applications for which the cathode ray tube (CRT) is unsuited. One particularly important application of laser systems is that of large screen multicolor display. Such systems have been successfully developed in a number of laboratories² including Zenith, Texas Instruments, General Telephone and Electronics, and Hitachi. In general, they are complicated, expensive, and required a substantial and careful engineering effort. A major source of engineering complication has been the necessity of using three separately modulated laser beams of different colors to achieve the desired color gamut and the use in many cases of mechanical scanning motion. We have found that a greater freedom of action as well as possible simplifications could result by using photoluminescent screens to provide some switching action between colors. In this paper we will describe some schemes for color switching and the

systems they make possible. We will also report experimental results of a particularly simple large screen black and white system which is speckle-free and provides PICTUREPHONE resolution.

In discussing laser display systems it is instructive to compare them with the conventional CRT systems. Recent technological advances in acoustooptics^{3,4} and electrooptics⁵ permit efficient and inertialess modulation and scanning of laser beams at rates approaching or comparable with those of electron beams in television CRT's. The principal difference between laser and CRT systems is not in resolution but in screen shape and size. Laser systems are inherently projection systems which can use flat screens; while the conventional CRT, which is most often directly viewed, has considerable volume. Generally, the size of a CRT screen is limited by mechanical considerations to at most 76 cm in diameter.⁶ Even if the CRT image is projected, the viewing area is constrained by the light intensity that can be developed at the CRT screen. In order to provide a black and white picture with brightness comparable with that of a typical motion picture display the projection CRT screen size is limited to approximately 2 m² even with anode voltages on the order of 75,000 V, where x-ray radiation and heat dissipation become serious problems.⁶ In contrast, screen heat dissipation is not a problem in laser displays since the beam is directly projected to as large an area as can be comfortably viewed with the available laser intensity. A rough estimate of the relation between light intensity and viewing area is that 1 W to 2 W of

The authors are with Bell Telephone Laboratories, Inc., Murray Hill, New Jersey 07974.

Received 16 March 1970.

available laser light are required for each square meter of a diffusing screen to achieve typical television brightness levels,⁷ while a factor of 3 less in intensity is satisfactory for theater viewing. For certain applications, directional screens can be used which reduce the required laser power by factors of up to several hundred.

The laser source is a limiting factor in many display system designs. By taking advantage of photoluminescent color conversion we can remove spectral constraints imposed by the limited number of practical laser emission wavelengths. Of the presently known laser types, the argon ion laser has already proven satisfactory for long term stable operation at a level of several watts,⁸ and experimental units have demonstrated outputs up to 100 W.⁹ Although this laser is satisfactory for a display system source in almost all respects, its efficiency is typically only on the order of several hundredths of 1%.¹⁰ Thus an argon laser source adequate to illuminate a 1 m² screen would require several kilowatts of electrical power. In comparison, only a few watts of electrical power are needed for modulation and scanning of the laser beam.³ Because of this laser inefficiency the operating expense for a display system using an argon laser source will tend to limit its applications either to commercial uses involving large audiences or uses where very low light intensities are acceptable. However, it should be pointed out that low efficiency is certainly not fundamental to laser operation. For example, operation of an infrared (10600 Å) Nd:YAG laser at 2.4% efficiency has already been demonstrated,¹¹ and efficiencies of approximately 10% appear to be possible.¹²

For the present, however, the argon ion laser is the most suitable prototype for a display system source. It has prominent emission lines in the blue (4880 Å) and green (5145 Å). Because photoluminescent conversion can only produce light of a similar or longer wavelength, it is essential that the source have at least one blue or ultraviolet emission. The additional emission of a second color, such as the green line of the argon laser, can be used to advantage in certain systems that will be discussed in Sec. III. By using phosphors described in Part I,¹ it is possible to convert a portion of the blue-green beam into red, which is the remaining component necessary for a multicolor display. This technique is substantially simpler than the alternate approach taken by others² of adding an additional red laser source to the display system and avoids the problem that presently available red lasers are even less suitable for a display system than the argon laser. The two principal choices are the He-Ne laser (6328 Å), which is inherently limited to low power operation for reasonable sizes by the low gain per unit length,¹³ and the krypton ion laser (6471 Å), which is nearly an order of magnitude less efficient than the argon laser.¹⁴ An additional advantage of photoluminescence is that the converted light is incoherent so that the unpleasant granular or speckled texture generally associated with viewing diffusely scattered coherent light is eliminated.¹⁵

The recently developed Cd-He laser which emits in

the blue (4416 Å) should also serve as a useful prototype source, although its intensity is limited like that of the He-Ne laser.¹⁶ In addition to the above lasers, it is possible to make multicolor laser hybrids by combining two or more gases into a single laser tube.¹⁷ Experiments with mixed gas lasers which combine argon and krypton or He-Ne-Cd to achieve multicolor emission indicate that the over-all efficiency of the mixed systems are considerably less than optimized lasers having single components. For example, the red emission from a He-Ne-Cd laser has been observed to be only about one-fourth of that from an optimized He-Ne laser.¹⁷ Thus, the present hybrids have a serious problem because of their inefficiency.

II. Color Control

There are many analogies between display systems that use electron beam sources and those that use laser beams. For example, both types of beam can be used to illuminate a phosphor which in turn produces a visible color. In the standard color CRT display three spatially separated electron guns are used to illuminate, respectively, three different colored phosphors through a shadow mask. A similar technique is also practical with laser displays. Thus, one method for achieving multicolor is by illuminating from different spatial directions.

An alternate method for achieving a multicolor effect with a CRT is the use of a single electron gun which excites a white phosphor screen located behind a rotating multicolor wheel.¹⁸ Transparent red, blue, and green segments of the wheel sequentially appear in front of the CRT resulting in a repeating sequence of discrete color frames. The wheel rotates sufficiently fast so that an observer cannot distinguish the separate color frames but instead sees only the total effect. Variations on this approach can all be categorized as active (i.e., moving) screen methods. Similar methods are also possible with a laser system, although the screen may be substantially different from that used in the CRT system.

In addition to these well-known methods, which are applicable to both electron beam and laser beam illumination, there are several unique features of laser beams which can be used to advantage in achieving a multicolor system. First, the laser beam itself may provide at least one color, and in the important case of the argon ion laser there are two distinct colors. Next, a laser beam, or for that matter any light beam, has two orthogonal polarization states which can be used to transmit separate color information. And, finally, light beams can be brought to a focus in very short distances by passive elements such as plastic lenslets which can be made an integral part of a viewing screen.

The internationally accepted CIE chromaticity diagram¹⁹ shown in Fig. 1 can be used as a guide in assessing the color quality of a display system. In this diagram the saturated (monochromatic) colors are located on the perimeter of the horseshoe shaped plot, while colors of decreasing saturation approach illuminant C which is

Explore Litigation Insights

Docket Alarm provides insights to develop a more informed litigation strategy and the peace of mind of knowing you're on top of things.

Real-Time Litigation Alerts



Keep your litigation team up-to-date with **real-time alerts** and advanced team management tools built for the enterprise, all while greatly reducing PACER spend.

Our comprehensive service means we can handle Federal, State, and Administrative courts across the country.

Advanced Docket Research



With over 230 million records, Docket Alarm's cloud-native docket research platform finds what other services can't. Coverage includes Federal, State, plus PTAB, TTAB, ITC and NLRB decisions, all in one place.

Identify arguments that have been successful in the past with full text, pinpoint searching. Link to case law cited within any court document via Fastcase.

Analytics At Your Fingertips



Learn what happened the last time a particular judge, opposing counsel or company faced cases similar to yours.

Advanced out-of-the-box PTAB and TTAB analytics are always at your fingertips.

API

Docket Alarm offers a powerful API (application programming interface) to developers that want to integrate case filings into their apps.

LAW FIRMS

Build custom dashboards for your attorneys and clients with live data direct from the court.

Automate many repetitive legal tasks like conflict checks, document management, and marketing.

FINANCIAL INSTITUTIONS

Litigation and bankruptcy checks for companies and debtors.

E-DISCOVERY AND LEGAL VENDORS

Sync your system to PACER to automate legal marketing.